



Test Report: DRS-240-24

240W All-In-One Intelligent Security Power

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Control Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test

■ RELIABILITY TEST


ENVIRONMENT TEST

■ DESIGN VERIFY TEST


OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	OUTPUT VOLTAGE(Max) TOLERANCE	V1: -1.0 %~ +1.0 %	I/P: 90VAC /305VAC O/P:FULL/ MIN. LOAD Ta:25°C	V1: -0.13%~ 0.13%
2	LINE REGULATION (Max)	V1: -0.5 %~ +0.5 %	I/P: 90VAC~ 305VAC O/P:FULL LOAD Ta:25°C	V1: -0.01%~0.01%
3	LOAD REGULATION(Max)	V1: -0.5 %~ +0.5 %	I/P: 230VAC O/P:FULL ~MIN LOAD Ta:25°C	V1: -0.13%~ 0.13%
4	OVER/UNDERSHOOT TEST	< ±5%	I/P: 230VAC O/P:FULL LOAD Ta:25°C	0.4%
5	RIPPLE & NOISE(Max)	V1: 240mVp-p	I/P:230VAC O/P: TESTING LOAD Ta:25°C	V1: 55mVp-p

high frequency :




low frequency :



6	SET UP TIME(Max)	230VAC/2400ms 115VAC/2400ms	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/275.4ms 115VAC/275.7ms
---	------------------	--------------------------------	--	----------------------------------


INPUT=230VAC/50HZ @ FULL LOAD

CH1 : Output Voltage CH2 : AC Input Voltage



INPUT=115VAC/60HZ @ FULL LOAD

CH1 : Output Voltage CH2 : AC Input Voltage




7	RISE TIME (Max)	230VAC/1000ms 115VAC/1000ms	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/157ms 115VAC/126.8ms
INPUT=230VAC/50HZ @ FULL LOAD		INPUT=115VAC/60HZ @ FULL LOAD		
CH1 : Output Voltage		CH1 : Output Voltage		
8	HOLD UP TIME (Typ.)	230VAC/16ms 115VAC/10ms	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/46.6ms 115VAC/44.4ms
INPUT=230VAC/50HZ @ FULL LOAD		INPUT=115VAC/60HZ @ FULL LOAD		
CH1 : Output Voltage CH2 : AC Input Voltage		CH1 : Output Voltage CH2 : AC Input Voltage		
9	DYNAMIC LOAD	V1: 2400mVp-p	I/P: 230VAC O/P: (1)FULL /50% LOAD 50%DUTY / 120HZ (2)FULL /50% LOAD 50%DUTY / 1KHZ Ta:25°C	(1)217mVp-p (2)198mVp-p
FULL /50% LOAD 50%DUTY / 120HZ		FULL /50% LOAD 50%DUTY / 1KHZ		

10	TRANSIENT RECOVERY TIME	V1: 2400mVp-p	I/P: 230VAC O/P:40% LOAD CHANGE 50%DUTY/120HZ 1.25A/us	519mVp-p
----	-------------------------	---------------	--	----------

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	INPUT VOLTAGE RANGE	90VAC~305VAC 127VDC~ 431VDC	(1) I/P:TESTING O/P:FULL LOAD (2) I/P:DC TESTING(L:+ N:-) O/P: FULL / 50% LOAD (3) I/P:DC TESTING(L:- N:+) O/P: FULL / 50% LOAD Ta:25°C I/P: LOW-LINE=90 V HIGH-LINE+10=315 V O/P:FULL/MIN LOAD (PLEASE CHECK DERATING CURVE) ON: 30 Sec OFF: 30 Sec 10MIN (POWER ON/OFF NO DAMAGE)	(1) 87.7V~305V/full load 87.7V~305V/90% load (2) 118Vdc~431Vdc/FULL LOAD 118Vdc~431Vdc/50% LOAD (3) 118Vdc~431Vdc/FULL LOAD 118Vdc~431Vdc/50% LOAD TEST: OK
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE	I/P:90 VAC ~305VAC O/P:FULL~MIN LOAD Ta:25°C	TEST: OK
3	INPUT CURRENT (Typ.)	230V/ 1.4 A 115V/2.8 A	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	I =1.16A/ 230VAC I =2.31A/ 115VAC
4	POWER FACTOR (Typ.)	0.95/ 230VAC 0.98/115VAC	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	PF=0.963/230VAC PF=0.992/115VAC

P.F vs LOAD



5	EFFICIENCY(Typ.)	92%	I/P:230 VAC O/P:FULL LOAD Ta:25°C	92.7%
<p>EFFICIENCY vs LOAD</p>				
6	INRUSH CURRENT(Typ.)	230V/60A 115V/30A COLD START	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	I =38.8A/ 230VAC I =20.2A/ 115VAC T50= 1.11ms/230V
<div style="display: flex; justify-content: space-around;"> <div style="width: 45%;"> <p>INPUT=230VAC/50HZ @ FULL LOAD CH2 : AC Input Voltage CH4 : Input current</p> </div> <div style="width: 45%;"> <p>INPUT=115VAC/ 60HZ @ FULL LOAD CH2 : AC Input Voltage CH4 : Input current</p> </div> </div>				











































PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	OVER LOAD PROTECTION	105%~135 % Protection type: Constant current limiting, shutdown output voltage after 5 sec	I/P: 305VAC I/P: 230VAC I/P: 100VAC O/P:TESTING Ta:25°C	117.3%/ 305VAC 117.3%/ 230VAC 117.3%/100VAC Protection type: Constant current limiting, shutdown output voltage after 5 sec

2	OVER VOLTAGE PROTECTION	Load main output : 32.4V~37.3V Protection type : Shut down o/p voltage, re-power on to recover	I/P: 305VAC I/P: 230VAC I/P: 90VAC O/P:MIN LOAD Ta:25°C	34.3V/ 305VAC 34.3V/ 230VAC 34.3V/ 90VAC Protection type : Shut down o/p voltage, re-power on to recover
3	OVER TEMPERATURE PROTECTION	Automatically drop load with temperature only for bat. load Shut down o/p voltage, recovers automatically after temperature goes down	I/P: 305VAC I/P: 90VAC O/P:FULL LOAD	O.T.P. Active Automatically drop load with temperature only for bat. load Shut down o/p voltage, recovers automatically after temperature goes down
4	SHORT PROTECTION	Constant current Range: 10.5A-13.5A 1 HOUR NO DAMAGE	I/P: 305VAC I/P: 90VAC O/P: FULL LOAD Ta:25°C	NO DAMAGE Constant current Range: <u>11.73</u> A PROTECTION TYPE : Constant current limiting, shutdown output voltage after 5 sec, re-power on
5	BATTER CUT OFF	20.9±0.5V	I/P: 230 VAC O/P:BAT. LOAD Ta:25°C	<u>20.92</u> V
6	REVERSE POLARITY	By internal MOSFET, no damage, recovers automatically after fault condition is removed.	I/P: 230 VAC O/P:BAT. LOAD Ta:25°C	By internal MOSFET, no damage, recovers automatically after fault condition is removed.

CONTROL FUNCTION TEST

N O	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	FORM-C RELAY	AC FAIL	Signals AC failure and activates when input voltage drops below : 79~89V of 120VAC, 132~187 of 220VAC. Relay contact output, ON : AC OK ; OFF : AC Fail ; max. rating : 30V/1A	TEST : <u>OK</u> <u>84.9V</u> of 120VAC, <u>174.4V</u> of 220VAC.
		CHARGER FAIL	Relay contact output, ON : Charger OK ; OFF : Charger Fail ; max. rating : 30V/1A	TEST : <u>OK</u>

		DC OK	Signals normal DC output and activates when output voltage > 90% rated value. Relay contact output, ON : DC OK ; OFF : DC Fail ; max. rating : 30V/1A	TEST : <u>21.67V</u>																																		
		BATTERY LOW/ ABNORMAL/ DISCONNECTED	Relay contact output, ON : Battery OK ; OFF : Battery Low ; max. rating : 30V/1A ; Battery low voltage : < 22V	TEST : <u>OK</u> <u>Vbat < 22.03V</u>																																		
2	BATTERY START	Restart system directly from battery and does not require AC power	I/P: BAT O/P:FULL LOAD Ta:25°C	TEST : <u>OK</u>																																		
3	DC-UPS	UPS switch to battery power within 10ms of AC failure	I/P: 230 VAC O/P:BAT. LOAD Ta:25°C	TEST : <u>OK</u>																																		
4	ADJUSTABLE CURRENT RANGE	20% ~ 100% charging current adjustable by VR	I/P : 230 VAC O/P : TESTING LOAD Ta : 25°C	17% ~100.2%																																		
5	LED INDICATOR	<p>4.LED alarm</p> <table border="1"> <thead> <tr> <th>Function</th> <th>Description</th> <th>Output of alarm</th> </tr> </thead> <tbody> <tr> <td rowspan="2">AC fail</td> <td>AC fail</td> <td>Red ●</td> </tr> <tr> <td>AC OK</td> <td>OFF ○</td> </tr> <tr> <td rowspan="2">DC OK</td> <td>DC fail</td> <td>OFF ○</td> </tr> <tr> <td>DC OK</td> <td>Green ●</td> </tr> <tr> <td rowspan="2">Charging status</td> <td>Float</td> <td>Green ●</td> </tr> <tr> <td>Charging: CC/CV</td> <td>Orange ●</td> </tr> <tr> <td rowspan="7">Status</td> <td rowspan="7">System diagnosis</td> <td>Charger fail</td> <td>Red : 1 Blink/Pause  </td> </tr> <tr> <td>Battery overvoltage / Battery reverse polarity</td> <td>Red : 2 Blink/Pause  </td> </tr> <tr> <td>Battery low / No Battery</td> <td>Red : 3 Blink/Pause  </td> </tr> <tr> <td>Battery discharge peak power > 4 min.</td> <td>Red : 4 Blink/Pause  </td> </tr> <tr> <td>Over load / short</td> <td>Red : 5 Blink/Pause  </td> </tr> <tr> <td>Over temperature</td> <td>Red : 6 Blink/Pause  </td> </tr> <tr> <td>Communication error</td> <td>Red : 7 Blink/Pause  </td> </tr> </tbody> </table> <p>I/P: TESTING VAC O/P:TESTING LOAD Ta:25°C</p>		Function	Description	Output of alarm	AC fail	AC fail	Red ●	AC OK	OFF ○	DC OK	DC fail	OFF ○	DC OK	Green ●	Charging status	Float	Green ●	Charging: CC/CV	Orange ●	Status	System diagnosis	Charger fail	Red : 1 Blink/Pause  	Battery overvoltage / Battery reverse polarity	Red : 2 Blink/Pause  	Battery low / No Battery	Red : 3 Blink/Pause  	Battery discharge peak power > 4 min.	Red : 4 Blink/Pause  	Over load / short	Red : 5 Blink/Pause  	Over temperature	Red : 6 Blink/Pause  	Communication error	Red : 7 Blink/Pause  	TEST : <u>OK</u>
Function	Description	Output of alarm																																				
AC fail	AC fail	Red ●																																				
	AC OK	OFF ○																																				
DC OK	DC fail	OFF ○																																				
	DC OK	Green ●																																				
Charging status	Float	Green ●																																				
	Charging: CC/CV	Orange ●																																				
Status	System diagnosis	Charger fail	Red : 1 Blink/Pause  																																			
		Battery overvoltage / Battery reverse polarity	Red : 2 Blink/Pause  																																			
		Battery low / No Battery	Red : 3 Blink/Pause  																																			
		Battery discharge peak power > 4 min.	Red : 4 Blink/Pause  																																			
		Over load / short	Red : 5 Blink/Pause  																																			
		Over temperature	Red : 6 Blink/Pause  																																			
		Communication error	Red : 7 Blink/Pause  																																			
6	FORCE BUTTON	Bat over discharge protection < 70%Bat rated	I/P: BAT O/P:FULL LOAD Ta:25°C	TEST : <u>OK(16.81V) 70%</u>																																		
7	Battery Discharge Peak power	a) 2 Peak power > 4 min ; b) 3 Peak power > 4 s ;	I/P: 230 VAC O/P:BAT. LOAD Ta:25°C	a) TEST : <u>OK</u> b) TEST : <u>OK</u>																																		

8	TEMPERATURE COMPENSATION	I/P: 230 VAC O/P: BAT. LOAD Ta:25°C			
		Constant Voltage			
		SPEC:	Ta=0°C (17K Ω)	Ta=25°C (5K Ω)	Ta=50°C (1.7K Ω)
			29.7±0.24V	28.8±0.24V	28.26±0.24V
	TEST RESULT:	29.50V	28.741V	28.15V	

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	PWM Transistor (D to S) or (C to E) Peak Voltage	Q 15/Q16ated : 18A/ 600V	AC ON/OFF I/P: High-Line +3V =308V VDS: O/P:(1) Full Load (2) Output Short (3) Dynamic Load Full Load/ Min. Load 90%Duty/1KHz (4) Dynamic Load Full Load/ Min. Load 90%Duty/3KHz (5) Dynamic Load Full Load/ Min. Load 90%Duty/5KHz (6) Dynamic Load 100% Load/ Min. Load 50%Duty/120Hz (7)0%→400% Load. Ta:25°C	Q15 VDS: (1) 452V (2) 488V (3) 452V (4) 452V (5) 452V (6) 452V (7) 452V Q16 VDS: (1) 444V (2) 484V (3) 444V (4) 444V (5) 448V (6) 444V (7) 444V
2	P.F.C Transistor (D to S) or (C to E) Peak Voltage	Q1 Rated : 13A/ 600V	I/P: High-Line +3V =308V AC ON/OFF O/P: (1)Full Load (2)Output Short (3) Dynamic Load Full Load/ Min. Load 90%Duty/1KHz (4) Dynamic Load Full Load/ Min. Load 90%Duty/3KHz (5) Dynamic Load Full Load/ Min. Load 90%Duty/5KHz (6) Dynamic Load 100% Load/ Min. Load 50%Duty/120Hz (7)0%→400% Load. Ta:25°C	Q1 VDS: (1) 549V (2) 528V (3) 545V (4) 541V (5) 545V (6) 508V (7) 496V
3	AUX MOS	U505 Rated : 1.04A/ 725 V Q504 Rated : 28 A/ 150 V	I/P: High-Line +3V =308 V AC ON/OFF O/P: (1)Full Load (2)Output Short (3) Dynamic Load Full Load/	U505 VDS: (1) 649V (2) 661V (3) 651V Q504 VDS: (1) 40.6V (2) 40.0V (3) 40.6V

			<p>Min. Load 90%Duty/1KHz (4) Dynamic Load Full Load/ Min. Load 90%Duty/3KHz (5) Dynamic Load Full Load/ Min. Load 90%Duty/5KHz (6) Dynamic Load 100% Load/ Min. Load 50%Duty/120Hz (7)0%→400% Load. Ta:25°C</p>	<p>(4) 657V (5) 651V (6) 651V (7) 657V</p>	<p>(4) 40.6V (5) 40.3V (6) 40.3V (7) 38.6V</p>
4	P.F.C DIODE	D 8 Rated : 8A/600V	<p>I/P:High-Line +3V =308V AC ON/OFF O/P: (1)Full Load (2)Output Short (3)Dynamic Load Full Load/ Min. Load 90%Duty/5KHz (4)Dynamic Load 100% Load/ Min. Load 50%Duty/120Hz Ta:25°C</p>	<p>(1) 558V (2) 550V (3) 554V (4) 531V</p>	
5	Diode Peak Voltage	Q101/Q102 Rated : 85A/100V	<p>AC ON/OFF I/P:High-Line +3V =308V O/P: (1)Full Load (2)Output Short (3)Dynamic Load Full Load/ Min. Load 90%Duty/1KHz (4)Dynamic Load Full Load/ Min. Load 90%Duty/3KHz (5)Dynamic Load Full Load/ Min. Load 90%Duty/5KHz (6)Dynamic Load 100% Load/ Min. Load 50%Duty/120Hz (7)0%→400% Load. (8).NO LOAD Ta:25°C</p>	<p>Q101: VDS: (1) 66.8V (2) 69.0V (3) 66.8V (4) 66.8V (5) 65.6V (6) 66.2V (7) 64.5 V (8) 60.6V</p>	<p>Q102: VDS: (1) 67.9V (2) 71.3V (3) 67.9V (4) 67.9V (5) 67.3V (6) 67.9V (7) 67.9V (8) 64.5V</p>
6	Input Capacitor Voltage	C5 Rated: : 150 μ / 450 V	<p>I/P:High-Line +3V =308V O/P: (1)Full Load input on/off (2) Min load input on /Off (3)Full Load /Min load Change (4)Full load continue Ta:25°C</p>	<p>(1) 445V (2) 425V (3) 449V (4) 445V</p>	
7	Control IC Voltage Test	<p>PWM IC U3 Rated 8.9V~15.5V PFC IC U1 Rated 9.75V~ 35V O/P IC U100 Rated 8V~24V IC U801 Rated 4.5V~36V</p>	<p>AC ON/OFF I/P:High-Line +3V =308V O/P(1)FULL LOAD (2) Output Short (3)O.L.P (4)O.V.P. (5)NO LOAD (LOW LINE) Ta:25°C</p>	<p>U3 (1) 13.8V (2) 13.5V (3) 13.5V (4) 13.5V (5) 13.8V</p>	<p>U801 (1) 12.4V (2) 12.4V (3) 12.4V (4) 12.4V (5) 12.4V</p> <p>U1 (1) 14.5V (2) 14.5V</p> <p>U502 (1) 11.7V (2) 11.7V</p>

		MCU U303 Rated 2.4V~3.6V		(3) 14.2V (4) 14.2V (5) 14.5V	(3) 11.7V (4) 11.7V (5) 11.7V
		AUX IC U502 Rated 8.5V~30V		U100 (1) 12.8V (2) 14.7V (3) 12.3V (4) 12.4V (5) 12.5V	U303 (1) 3.37V (2) 3.31V (3) 3.37V (4) 3.31V (5) 3.31V

■ SAFETY& E.M.C. TEST

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	WITHSTAND VOLTAGE	I/P-O/P: 4 KVAC/min I/P-FG: 2 KVAC/min O/P-FG:1.5 KVAC/min	I/P-O/P: 4.2 KVAC/min I/P-FG: 2.4 KVAC/min O/P-FG:1.8 KVAC/min Ta:25°C	I/P-O/P:10.12mA I/P-FG:8.41mA O/P-FG:18.99m A NO DAMAGE
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ I/P-FG: 500VDC>100MΩ O/P-FG:500VDC>100MΩ	I/P-O/P: 500 VDC I/P-FG: 500 VDC O/P-FG: 500 VDC Ta:25°C	I/P-O/P:9999MΩ I/P-FG: 9999MΩ O/P-FG: 9999MΩ NO DAMAGE
3	GROUNDING CONTINUITY	FG(PE) TO CHASSIS OR TRACE < 100 mΩ	40A / 2min Ta:25°C	6mΩ

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	HARMONIC	EN61000-3-2 CLASS A	I/P:230VAC/50HZ O/P:FULL LOAD Ta:25°C	PASS
2	CONDUCTION	EN55032 CLASS B	I/P : 230 VAC (50HZ) O/P : FULL/50% LOAD Ta : 25°C	PASS Test by certified Lab
3	RADIATION	EN55032 CLASS B	I/P : 230 VAC (50HZ) O/P : FULL LOAD Ta : 25°C	PASS Test by certified Lab
4	E.S.D	EN61000-4-2 AIR : 8KV / Contact : 4KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	■ CRITERIA A
5	E.F.T	EN61000-4-4 INPUT : 2KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	■ CRITERIA A

6	SURGE	IEC61000-4-5 L-N : 1KV L,N-PE : 2KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	■ CRITERIA A
7	Test by certified Lab & Test Report Prepare Any contradictions of the test results, please refer to the latest EMC test report			

■ RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																																																																																				
1	TEMPERATURE RISE TEST	MODEL : DRS-240-24 1. ROOM AMBIENT BURN-IN : 2 HRS I/P : 230VAC O/P : FULL LOAD Ta= 25.0 °C 2. HIGH AMBIENT BURN-IN : 2 HRS I/P : 230VAC O/P : FULL LOAD Ta= 50.0 °C																																																																																																						
				<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>ROOM AMBIENT Ta= 25.0°C</th> <th>HIGH AMBIENT Ta= 50.0 °C</th> </tr> </thead> <tbody> <tr><td>1</td><td>LF1</td><td>32.0°C</td><td>60.0°C</td></tr> <tr><td>2</td><td>C3</td><td>38.8°C</td><td>67.0°C</td></tr> <tr><td>3</td><td>LF2</td><td>38.6°C</td><td>67.0°C</td></tr> <tr><td>4</td><td>RTH4</td><td>43.1°C</td><td>69.7°C</td></tr> <tr><td>5</td><td>RTH1</td><td>38.5°C</td><td>66.6°C</td></tr> <tr><td>6</td><td>C26</td><td>42.6°C</td><td>69.1°C</td></tr> <tr><td>7</td><td>BD1</td><td>51.6°C</td><td>75.4°C</td></tr> <tr><td>8</td><td>C10</td><td>44.7°C</td><td>71.7°C</td></tr> <tr><td>9</td><td>L3</td><td>44.7°C</td><td>71.8°C</td></tr> <tr><td>10</td><td>C5</td><td>47.8°C</td><td>69.5°C</td></tr> <tr><td>11</td><td>D12</td><td>45.2°C</td><td>72.1°C</td></tr> <tr><td>12</td><td>L1</td><td>46.3°C</td><td>72.1°C</td></tr> <tr><td>13</td><td>Q2</td><td>50.8°C</td><td>78.4°C</td></tr> <tr><td>14</td><td>R4</td><td>48.9°C</td><td>74.7°C</td></tr> <tr><td>15</td><td>U1</td><td>42.0°C</td><td>69.1°C</td></tr> <tr><td>16</td><td>U4</td><td>42.8°C</td><td>69.4°C</td></tr> <tr><td>17</td><td>C39</td><td>42.8°C</td><td>69.4°C</td></tr> <tr><td>18</td><td>U502</td><td>52.0°C</td><td>77.8°C</td></tr> <tr><td>19</td><td>T600</td><td>41.9°C</td><td>69.9°C</td></tr> <tr><td>20</td><td>T500</td><td>42.5°C</td><td>67.7°C</td></tr> <tr><td>21</td><td>U3</td><td>43.8°C</td><td>71.3°C</td></tr> <tr><td>22</td><td>Q504</td><td>45.8°C</td><td>72.1°C</td></tr> <tr><td>23</td><td>Q15</td><td>46.2°C</td><td>73.4°C</td></tr> <tr><td>24</td><td>T1coil</td><td>74.0°C</td><td>103.6°C</td></tr> </tbody> </table>	NO	Position	ROOM AMBIENT Ta= 25.0°C	HIGH AMBIENT Ta= 50.0 °C	1	LF1	32.0°C	60.0°C	2	C3	38.8°C	67.0°C	3	LF2	38.6°C	67.0°C	4	RTH4	43.1°C	69.7°C	5	RTH1	38.5°C	66.6°C	6	C26	42.6°C	69.1°C	7	BD1	51.6°C	75.4°C	8	C10	44.7°C	71.7°C	9	L3	44.7°C	71.8°C	10	C5	47.8°C	69.5°C	11	D12	45.2°C	72.1°C	12	L1	46.3°C	72.1°C	13	Q2	50.8°C	78.4°C	14	R4	48.9°C	74.7°C	15	U1	42.0°C	69.1°C	16	U4	42.8°C	69.4°C	17	C39	42.8°C	69.4°C	18	U502	52.0°C	77.8°C	19	T600	41.9°C	69.9°C	20	T500	42.5°C	67.7°C	21	U3	43.8°C	71.3°C	22	Q504	45.8°C	72.1°C	23	Q15	46.2°C	73.4°C	24	T1coil	74.0°C	103.6°C
NO	Position	ROOM AMBIENT Ta= 25.0°C	HIGH AMBIENT Ta= 50.0 °C																																																																																																					
1	LF1	32.0°C	60.0°C																																																																																																					
2	C3	38.8°C	67.0°C																																																																																																					
3	LF2	38.6°C	67.0°C																																																																																																					
4	RTH4	43.1°C	69.7°C																																																																																																					
5	RTH1	38.5°C	66.6°C																																																																																																					
6	C26	42.6°C	69.1°C																																																																																																					
7	BD1	51.6°C	75.4°C																																																																																																					
8	C10	44.7°C	71.7°C																																																																																																					
9	L3	44.7°C	71.8°C																																																																																																					
10	C5	47.8°C	69.5°C																																																																																																					
11	D12	45.2°C	72.1°C																																																																																																					
12	L1	46.3°C	72.1°C																																																																																																					
13	Q2	50.8°C	78.4°C																																																																																																					
14	R4	48.9°C	74.7°C																																																																																																					
15	U1	42.0°C	69.1°C																																																																																																					
16	U4	42.8°C	69.4°C																																																																																																					
17	C39	42.8°C	69.4°C																																																																																																					
18	U502	52.0°C	77.8°C																																																																																																					
19	T600	41.9°C	69.9°C																																																																																																					
20	T500	42.5°C	67.7°C																																																																																																					
21	U3	43.8°C	71.3°C																																																																																																					
22	Q504	45.8°C	72.1°C																																																																																																					
23	Q15	46.2°C	73.4°C																																																																																																					
24	T1coil	74.0°C	103.6°C																																																																																																					

		NO	Position	ROOM AMBIENT Ta= 25.0°C	HIGH AMBIENT Ta= 50.0 °C
		25	T1core	57.3°C	83.4°C
		26	C60	45.6°C	73.5°C
		27	RTH5	51.0°C	78.6°C
		28	C106	41.9°C	70.3°C
		29	LF100	50.1°C	78.8°C
		30	U100	56.8°C	84.6°C
		31	Q102	51.5°C	80.5°C
		32	Q522	31.6°C	59.5°C
		33	C103	48.5°C	76.7°C
		34	Q303	32.0°C	59.6°C
		35	Q350	36.8°C	64.6°C
		36	D503	44.2°C	70.9°C
		37	U505	51.9°C	78.0°C
		38	Q500	44.8°C	72.3°C
		39	U303	42.5°C	70.3°C
		40	U801	42.6°C	70.5°C
		41	U150	43.3°C	71.2°C
2	OVER LOAD BURN-IN TEST	NO DAMAGE 1 HOUR (MIN)		I/P : 230 VAC O/P : 118%LOAD Ta : 25°C	TEST : OK
3	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR		I/P : 264VAC/100VAC O/P : 100%LOAD Ta= -35°C	TEST : OK
4	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 50 °C/95 %R.H NO DAMAGE		I/P : 272 VAC O/P : FULL LOAD Ta=50.7°C HUMIDITY= 95 %R.H	TEST : OK
5	TEMPERATURE COEFFICIENT	± 0.03%/°C(0~50°C)		I/P : 230 VAC O/P : FULL LOAD	±0.008%/°C(0~50°C)
6	STORAGE TEMPERATURE TEST	-40~85°C		1. Thermal shock Temperature : -45°C~ +90°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 10 CYCLE 5. Input/Output condition : STATIC	
7	THERMAL SHOCK TEST	-30~50°C		1. Thermal shock Temperature : -35°C~ +55°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 16 CYCLE 5. Input/Output condition : 15cycle:230V/ FULL LOAD AC ON 3sec/AC OFF 1sec TEST 1cycle:230V/ FULL LOAD Burn In Test	
8	VIBRATION TEST	10 ~ 500Hz, 5G 10min./1cycle, 60min. each along X, Y, Z axes		1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 10~500Hz (3) Sweep Time : 10min/sweep cycle (4) Acceleration : 6G (5) Test Time : 180min in each axis (X.Y.Z) (6) Ta : 25°C	



9	CAPACITOR LIFE CYCLE	SUPPOSE C103 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Ta= 25 °C LIFE TIME (2) I/P : 230VAC O/P : FULL LOAD Ta= 50 °C LIFE TIME (3) I/P : 230VAC O/P : 75% LOAD Ta= 50 °C LIFE TIME (4) I/P : 230VAC O/P : 50% LOAD Ta= 50 °C LIFE TIME	(1) 713178.7HRS (2) 100993.6HRS (3) 158323.3HRS (4) 220849.6HRS
10	MTBF	Conducted by Parts Stress Analysis Prediction 564.7K hrs min. Telcordia SR-332 (Bellcore) ; 73.3K hrs min. MIL-HDBK-217F (25°C)	
11	Ongoing Reliability Test	I/P : 230VAC O/P : FULL LOAD TA=50°C Demonstration Mean Time Between Failure : 30,000 hours	

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	Liutt		Wangdz

2020.10.1 TAG-QA-009