

ATTESTATION OF CONFORMITY

Issued to: MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd., Wugu District, 24891 New Taipei City, Taiwan

For the product: KNX controller

Trade name: MEAN WELL

Type/Model: KAA-8R, KAA-8R-10, KAA-8R-S, KAA-8R-10S
KAA-4R4V, KAA-4R4V-10, KAA-4R4V-S, KAA-4R4V-10S

Ratings: Supply: 21-31 Vdc, 6 mA max.; Output: 8 x 10 A Max. 16 MHz: KAA-8R, KAA-8R-10,
KAA-8R-S, KAA-8R-10S
Supply: 21-31 Vdc, 11 mA max.; Output: 4 x 10 A Max. and 4 x (0-10V) 16 MHz:
KAA-4R4V, KAA-4R4V-10, KAA-4R4V-S, KAA-4R4V-10S

Manufactured by: MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd., Wugu District, 24891 New Taipei City, Taiwan

Requirements: EN 60669-2-1:2004 + A1:2009 + A12:2010
EN 60669-2-5:2016
EN 60669-1:2018
EN IEC 63044-3:2018

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 4380596.50/ 52+4380595.50/51/52.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 29 October 2021

Number: 4380596.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,
Guangzhou Branch

Miranda Zhou
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

