



UK Declaration of Conformity

For the following equipment :

Product Name: Switching Power Supply

Model Designation: NPX-1700-Y (X=P,B;Y=12,24,48)

The designated product(s) is(are) in conformity with the relevant legislation:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012: SI 2012 No. 3032

Electrical Equipment (Safety) Regulations 2016 :

BS EN 62368-1:2014+A11:2017

Dekra certificate : 31-120921

BS EN 60335-1:2012+A15:2021

Dekra certificate : 31-120920

BS EN 60335-2-29:2021+A1:2021

Electrical Compatibility Regulations 2016 :

EMI (Electro-Magnetic Interference)

Conducted emission BS EN 55032:2015+A1:2020 Class B

Radiated emission BS EN 55032:2015+A1:2020 Class A

Harmonic current BS EN IEC 61000-3-2:2019+A1:2021

Voltage flicker BS EN 61000-3-3:2013+A1:2019

EMS (Electro-Magnetic Susceptibility)

BS EN 55024:2010+A1:2015 BS EN 55035:2017+A11:2020

ESD air BS EN 61000-4-2:2009 Level 3 8KV

ESD contact BS EN 61000-4-2:2009 Level 2 4KV

RF field susceptibility BS EN IEC 61000-4-3:2020 Level 2 3V/m

EFT bursts BS EN 61000-4-4:2012 Level 2 1KV/5KHz

Surge susceptibility BS EN 61000-4-5:2014+A1:2017 Level 3 1KV/Line-Line

Surge susceptibility BS EN 61000-4-5:2014+A1:2017 Level 3 2KV/Line-Earth

Conducted susceptibility BS EN 61000-4-6:2014 Level 2 3V

Magnetic field immunity BS EN 61000-4-8:2010 Level 1 1A/m

BS EN IEC 61000-4-11:2020

Voltage dip, interruption <5% residual voltage for 0.5 periods ,70% residual voltage for 25 periods , <5% residual voltage for 250 periods

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Regulations on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number SC3xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D :

(Name / Position)

Aries
(Signature)

Alex Tsai/ Director, Product Strategy Center :

(Name / Position)

[Signature]
(Signature)

Taiwan

(Place)

Apr. 10th, 2023

(Date)