

MODEL : RPT-75D

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	RIPPLE & NOISE	V1: 80 mVp-p (Max) V2: 200 mVp-p (Max) V3: 120 mVp-p (Max)	I/P: 230VAC O/P:FULL LOAD Ta:25°C	V1: 15 mVp-p (Max) V2: 26 mVp-p (Max) V3: 16 mVp-p (Max)	P
2	OUTPUT VOLTAGE ADJUST RANGE	CH1: 4.75 V~5.5 V	I/P: 230 VAC I/P: 115 VAC O/P:MIN LOAD Ta:25°C	4.55V~ 5.88 V / 230VAC 4.55V~ 5.88 V / 115VAC	P
3	OUTPUT VOLTAGE TOLERANCE	V1: 2 %~ -2 % (Max) V2: 8 %~ -8 % (Max) V3: 8 %~ -8 % (Max)	I/P: 100 VAC / 264 VAC O/P:FULL/ MIN LOAD Ta:25°C	V1: 0.12 %~ -0.12 % V2: 2.6 %~ -2.6 % V3: 3.4 %~ -3.4 %	P
4	LINE REGULATION	V1: 0.5 %~ -0.5 % (Max) V2: 1 %~ -1 % (Max) V3: 1 %~ -1 % (Max)	I/P: 100 VAC ~ 264 VAC O/P:FULL LOAD Ta:25°C	V1: 0 %~ 0 % V2: 0.28 %~ -0.28 % V3: 0.47 %~ -0.47 %	P
5	LOAD REGULATION	V1: 1.5 %~ -1.5 % (Max) V2: 3 %~ -3 % (Max) V3: 3 %~ -3 % (Max)	I/P: 230 VAC O/P:FULL ~MIN LOAD Ta:25°C	V1: 0 %~ 0 % V2: 1.4 %~ -1.4 % V3: 1 %~ -1 %	P
6	CROSS REGULATION	V1: 1.5 %~ -1.5 % (Max) V2: 3 %~ -3 % (Max) V3: 3 %~ -3 % (Max)	I/P: 230 VAC O/P: Testing O/P 60%LOAD Other O/P 40%LOAD Change Ta:25°C	V1: 0 %~ 0 % V2: 2.2 %~ -2.2 % V3: 2.7 %~ -2.7 %	P
7	SET UP TIME	230VAC: 500 ms (Max) 115 VAC: 500 ms (Max)	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	230VAC/ 150 ms 115VAC/ 111 ms	P
8	RISE TIME	230VAC: 30 ms (Max) 115VAC: 30 ms (Max)	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	230VAC/ 6 ms 115VAC/ 6 ms	P
9	HOLD UP TIME	230VAC: 90 ms (TYP) 115VAC: 20 ms (TYP)	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	230VAC/ 105 ms 115VAC/ 22.4 ms	P
10	OVER/UNDERSHOOT TEST	< ±5%	I/P: 230 VAC O/P:FULL LOAD Ta:25°C	TEST: <5 %	P
11	DYNAMIC LOAD	V1: 1000 mVp-p	I/P: 230 VAC O/P:FULL /Min LOAD 90%DUTY/1KHZ Ta:25°C	150 mVp-p	P

INPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	INPUT VOLTAGE RANGE	90VAC~264 VAC	I/P:TESTING O/P:FULL LOAD Ta:25°C	52V~264V	P
			I/P: LOW-LINE-3V= 87V HIGH-LINE+15%=300 V O/P:FULL/MIN LOAD ON: 30 Sec . OFF: 30 Sec 10MIN ( AC POWER ON/OFF NO DAMAGE )	TEST: OK	
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE OSC	I/P: 90VAC ~ 264 VAC O/P:FULL~MIN LOAD Ta:25°C	TEST: OK	P
3	EFFICIENCY	79% (TYP)	I/P: 230 VAC O/P:FULL LOAD Ta:25°C	79.4 %	P
4	INPUT CURRENT	230V/ 1 A (TYP) 115V/ 1.5 A (TYP)	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	I = 0.84 A/ 230 VAC I = 1.42 A/ 115 VAC	P
5	INRUSH CURRENT	230V/ 50 A (TYP) 115V/ 25 A (TYP) COLD START	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	I = 36 A/ 230 VAC I = 18 A/ 115 VAC	P
6	LEAKAGE CURRENT	< 150 uA/ 264 VAC for earth leakage current	I/P: 264 VAC O/P:Min LOAD Ta:25°C	L-FG: 119 uA N-FG: 119 uA	P
		< 100 uA/264 VAC for touch leakage current	I/P: 264 VAC O/P:Min LOAD Ta:25°C	L-V+ : 84 uA L-V-: 84 uA N-V+: 84 uA N-V-: 84 uA	P

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	140 %~ 180 %	I/P: 230 VAC I/P: 115 VAC O/P:TESTING Ta:25°C	168 %/ 230 VAC 161 %/ 115 VAC Hiccup Mode	P
2	OVER VOLTAGE PROTECTION	CH1: 5.75V~ 6.75V	I/P: 230 VAC I/P: 115 VAC O/P:MIN LOAD Ta:25°C	6.4 V/ 230 VAC 6.4 V/ 115 VAC Shunt down Re- power ON	P
3	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P: 264 VAC O/P:FULL LOAD Ta:25°C	NO DAMAGE Hiccup Mode	P

ENVIRONMENT TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT																																																																																										
1	TEMPERATURE RISE TEST	MODEL : RPT-75A WITH FAN 1. ROOM AMBIENT BURN-IN : 1HRS I/P: 230VAC O/P: FULL LOAD Ta=31.3°C 2. HIGH AMBIENT BURN-IN : 1.5HRS I/P: 230VAC O/P: FULL LOAD Ta=52.5°C			P																																																																																										
		<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>P/N</th> <th>ROOM AMBIENT Ta=31.3 °C</th> <th>HIGH AMBIENT Ta=52.5 °C</th> </tr> </thead> <tbody> <tr><td>1</td><td>BD1</td><td>US4K80 4A/800V SHI</td><td>50.6°C</td><td>70.3°C</td></tr> <tr><td>2</td><td>LF2</td><td>TR-719</td><td>52.8°C</td><td>70.7°C</td></tr> <tr><td>3</td><td>C6</td><td>100U/400V NCC 105°C</td><td>38.6°C</td><td>59.9°C</td></tr> <tr><td>4</td><td>C36</td><td>47U/50V RUB 105°C YXF</td><td>42.8°C</td><td>64.0°C</td></tr> <tr><td>5</td><td>T1COIL</td><td>TF-1524 JSI</td><td>66.6°C</td><td>89.9°C</td></tr> <tr><td>6</td><td>D1</td><td>HER308 3A/1KV REC</td><td>55.7°C</td><td>78.6°C</td></tr> <tr><td>7</td><td>ZD1</td><td>P6KE250A LT</td><td>39.4°C</td><td>63.9°C</td></tr> <tr><td>8</td><td>Q1</td><td>STP9NK70ZFP 7.5A/700V</td><td>55.2°C</td><td>78.8°C</td></tr> <tr><td>9</td><td>D100</td><td>STPS2045CT 20A/45V ST</td><td>58.5°C</td><td>83.0°C</td></tr> <tr><td>10</td><td>D200</td><td>SF10SC6 10A/60V SHI</td><td>66.6°C</td><td>90.4°C</td></tr> <tr><td>11</td><td>RG1</td><td>AN7905T</td><td>69.5°C</td><td>93.0°C</td></tr> <tr><td>12</td><td>D300</td><td>SR360 3A/60V</td><td>61.9°C</td><td>82.7°C</td></tr> <tr><td>13</td><td>C105</td><td>22000U/16V RUB 105°C</td><td>41.1°C</td><td>64.4°C</td></tr> <tr><td>14</td><td>C205</td><td>1000U/16V RUB 105°C ZLH</td><td>52.6°C</td><td>75.6°C</td></tr> <tr><td>15</td><td>C305</td><td>470U/25V NCC 105°C KY</td><td>56.6°C</td><td>78.4°C</td></tr> <tr><td>16</td><td>R3</td><td>68KΩ/2W R/MO</td><td>57.4°C</td><td>78.4°C</td></tr> <tr><td>17</td><td>U1</td><td>NCP1230D165R2 ON</td><td>39.2°C</td><td>60.4°C</td></tr> </tbody> </table>	NO	Position		P/N	ROOM AMBIENT Ta=31.3 °C	HIGH AMBIENT Ta=52.5 °C	1	BD1	US4K80 4A/800V SHI	50.6°C	70.3°C	2	LF2	TR-719	52.8°C	70.7°C	3	C6	100U/400V NCC 105°C	38.6°C	59.9°C	4	C36	47U/50V RUB 105°C YXF	42.8°C	64.0°C	5	T1COIL	TF-1524 JSI	66.6°C	89.9°C	6	D1	HER308 3A/1KV REC	55.7°C	78.6°C	7	ZD1	P6KE250A LT	39.4°C	63.9°C	8	Q1	STP9NK70ZFP 7.5A/700V	55.2°C	78.8°C	9	D100	STPS2045CT 20A/45V ST	58.5°C	83.0°C	10	D200	SF10SC6 10A/60V SHI	66.6°C	90.4°C	11	RG1	AN7905T	69.5°C	93.0°C	12	D300	SR360 3A/60V	61.9°C	82.7°C	13	C105	22000U/16V RUB 105°C	41.1°C	64.4°C	14	C205	1000U/16V RUB 105°C ZLH	52.6°C	75.6°C	15	C305	470U/25V NCC 105°C KY	56.6°C	78.4°C	16	R3	68KΩ/2W R/MO	57.4°C	78.4°C	17	U1	NCP1230D165R2 ON	39.2°C	60.4°C		
NO	Position	P/N	ROOM AMBIENT Ta=31.3 °C	HIGH AMBIENT Ta=52.5 °C																																																																																											
1	BD1	US4K80 4A/800V SHI	50.6°C	70.3°C																																																																																											
2	LF2	TR-719	52.8°C	70.7°C																																																																																											
3	C6	100U/400V NCC 105°C	38.6°C	59.9°C																																																																																											
4	C36	47U/50V RUB 105°C YXF	42.8°C	64.0°C																																																																																											
5	T1COIL	TF-1524 JSI	66.6°C	89.9°C																																																																																											
6	D1	HER308 3A/1KV REC	55.7°C	78.6°C																																																																																											
7	ZD1	P6KE250A LT	39.4°C	63.9°C																																																																																											
8	Q1	STP9NK70ZFP 7.5A/700V	55.2°C	78.8°C																																																																																											
9	D100	STPS2045CT 20A/45V ST	58.5°C	83.0°C																																																																																											
10	D200	SF10SC6 10A/60V SHI	66.6°C	90.4°C																																																																																											
11	RG1	AN7905T	69.5°C	93.0°C																																																																																											
12	D300	SR360 3A/60V	61.9°C	82.7°C																																																																																											
13	C105	22000U/16V RUB 105°C	41.1°C	64.4°C																																																																																											
14	C205	1000U/16V RUB 105°C ZLH	52.6°C	75.6°C																																																																																											
15	C305	470U/25V NCC 105°C KY	56.6°C	78.4°C																																																																																											
16	R3	68KΩ/2W R/MO	57.4°C	78.4°C																																																																																											
17	U1	NCP1230D165R2 ON	39.2°C	60.4°C																																																																																											
2	OVER LOAD BURN-IN TEST	NO DAMAGE 1 HOUR ( MIN )	I/P: 230 VAC O/P:V1=10A V2=5A V3=1A Ta:25°C	TEST : OK	P																																																																																										
3	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P: 230 VAC O/P: 100% LOAD Ta= -20°C	TEST : OK	P																																																																																										
4	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 50 °C NO DAMAGE	I/P: 272 VAC O/P:FULL LOAD Ta= 50 °C HUMIDITY= 95 %R.H	TEST : OK	P																																																																																										
5	TEMPERATURE COEFFICIENT	± 0.03 %/°C (0~45°C)	I/P: 230 VAC O/P:FULL LOAD	± 0.019 %/°C (0~50°C)	P																																																																																										
6	VIBRATION TEST	1 Carton & 1 Set (1) Waveform: Sine Wave (2) Frequency:10~500Hz (3) Sweep Time:10min/sweep cycle (4) Acceleration:2G (5) Test Time:1 hour in each axis (X.Y.Z) (6) Ta:25°C		TEST : OK	P																																																																																										

**SAFETY TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P: 4 KVAC/min I/P-FG: 2 KVAC/min O/P-FG: 1.5 KVAC/min	I/P-O/P: 4.2 KVAC/min I/P-FG: 2.4 KVAC/min O/P-FG: 1.8 KVAC/min Ta:25°C	I/P-O/P: 2.01 mA I/P-FG: 1.32 mA O/P-FG: 1.42 mA NO DAMAGE	P
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ I/P-FG: 500VDC>100MΩ O/P-FG:500VDC>100MΩ	I/P-O/P: 500 VDC I/P-FG: 500 VDC O/P-FG: 500 VDC Ta:25°C	I/P-O/P: 15 GΩ I/P-FG: 15 GΩ O/P-FG: 30 GΩ NO DAMAGE	P
3	APPROVAL	TUV: Certificate NO : TA 50096088 UL: File NO : E227340			P

**E.M.C TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	HARMONIC	EN61000-3-2 CLASS A	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	PASS	P
2	CONDUCTION	EN55011 CLASS B	I/P: 230 VAC (50HZ) O/P:FULL/50% LOAD Ta:25°C	PASS Test by certified Lab	P
3	RADIATION	EN55011 CLASS B	I/P: 230 VAC (50HZ) O/P:FULL LOAD Ta:25°C	PASS Test by certified Lab	P
4	E.S.D	EN61000-4-2 MEDICAL AIR:8KV / Contact:6KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	P
5	E.F.T	EN61000-4-4 MEDICAL INPUT: 2KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	P
6	SURGE	IEC61000-4-5 MEDICAL L-N :1KV L,N-PE:2KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	P
7	Test by certified Lab & Test Report Prepare				

**M.T.B.F & LIFE CYCLE CALCULATION**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	CAPACITOR LIFE CYCLE	RPT-75A WITH FAN : SUPPOSE C105 IS THE MOST CRITICAL COMPONENT I/P: 230VAC O/P:FULL LOAD Ta= 25 °C LIFE TIME= 1419902 HRS I/P: 230VAC O/P:FULL LOAD Ta= 50 °C LIFE TIME= 217049 HRS			P
2	MTBF	MIL-HDBK-217F NOTICES2 PARTS COUNT TOTAL FAILURE RATE: 521.2K HRS			P

COMPONENT STRESS TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	Power Transistor ( D to S) or (C to E) <b>Peak Voltage</b>	Q1 Rated STP9NK70ZFP : 700V 7.5A	I/P:High-Line +3V = 267 V O/P: (1)Full Load Turn on (2) Output Short Ta:25°C	(1) 646 V (2) 694 V	P
2	Diode <b>Peak Voltage</b>	D100 Rated STPS2045CT : 45V 20A  D200 Rated YG805C010R : 100V 20 A  D300 Rated HER303 : 200V 3A	I/P:High-Line +3V = 267 V O/P: (1)Full Load Turn on (2)Output Short Ta:25°C	(1) 42 V (2) 33 V  (1) 148 V (2) 132 V  (1) 116 V (2) 94 V	P
3	Clamp Diode <b>Peak Voltage</b>	D1 Rated HER308 : 1000V 3A	I/P:High-Line +3V = 267 V O/P: (1) Dynamic Load 90%Duty/1KHz Ta:25°C	(1) 570 V	P
4	Input Capacitor <b>Voltage</b>	C5 Rated : 100u / 400V/ 105°C	I/P:High-Line +3V = 267 V O/P: (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta:25°C	(1) 374 V (2) 380 V (3) 380 V	P
5	Control IC <b>Voltage Test</b>	U1 Rated 1230D165R2G : 18V	I/P:High-Line +3V = 267 V O/P: (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta:25°C	(1) 12.57 V (2) 11.74 V (3) 12.57 V	P

DATE	SAMPLE	TEST RESULT	TESTER	APPROVAL
2006/9/5	RD SAMPLE	PASS	VINCENT TSENG	MAX LIN
2006/11/14	PRODUCT SAMPLE W0610A20	PASS	VINCENT TSENG	MAX LIN
2007/5/9	PRODUCT SAMPLE W0703A31	PASS	VINCENT TSENG	MAX LIN

2003/12/12 A50-F023